

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1209:197 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: System Sensor, 3825 Ohio Ave, St Charles IL 60504
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Model SSK451 signaling accessory. Unit employs a remote test switch with notification device (for supplemental use only). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as a signaling accessory for use with separately listed compatible fire alarm control units. Authority having jurisdiction shall be consulted prior to installation. The notification devices are supplemental and are not approved for use as the primary fire alarm notification signal appliance.

Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager